



From normal incoming power through Disconnecting Means (IS/CB)



**Starting Method:** Reduced Voltage

Wye-delta open

**Typical Voltage Applied at Start:** 100%

**Inrush Current:** 33% of normal load current

**Starting Torque:** 33%

**Motor Type:** Wye-delta

**No. of Contactors:** 2 at 58%, 1 at 33% of motor full load current (FLC)

**Min. ampacity of motor conductors:** 6 at 125% x 58% of FLC